

STATEMENT OF WORK

SOW-02-837-1-08407A-2/1

FOR THE IROAN OF THE

REFRIGERATOR-CONTAINER, FIELD

NSN: 4110-01-107-9078

TAMCN: B17107B

ID# 08407A

17 OCTOBER 00

Table of Content

<u>Section and Reading</u>	<u>Page</u>
1.0 Scope	1
1.1 Background	1
2.0 Applicable Documents	1
2.1 Military Standards	1
2.2 Other Government Documents and Publications	1
2.3 Industry Standards	2
3.0 Requirements	2
3.1 General Tasks	2
3.2 Detail Tasks	3
3.2.1 Phase I - Pre-Induction	3
3.2.2 Phase II - IROAN	3
3.2.3 Phase III - Inspection, Testing and Acceptance	4
3.2.4 Phase IV - Packaging, Handling, Storage and Transportation (PHS&T)	4
3.3 Configuration Control	4
3.4 Electrostatic Discharge (ESD) Control Program	5
3.5 Quality Assurance Provisions	5
3.6 Acceptance	5
3.7 Government Furnished Equipment Accountability (GFE)/Government Furnished Material (GFM)	5
3.8 Contractor Furnished Materiel (CFM)	5
3.9 Rejection	6
Appendix A Refrigerator-Container Pre-Induction Inspection Checklist	A-1

STATEMENT OF WORK FOR THE
REFRIGERATOR-CONTAINER, FIELD, 350 CUFT
Inspect Repair Only As Necessary (IROAN)
4110-01-107-9078

1.0 SCOPE. This Statement of Work (SOW) establishes and sets forth tasks and identifies the work efforts that shall be performed by the Contractor in the IROAN effort of the REFRIGERATOR-CONTAINER, FIELD, 350 CUFT, hereafter referred to as the REFRIGERATOR-CONTAINER. This document contains requirements to restore the REFRIGERATOR-CONTAINER to Condition Code "A." Condition Code A is defined as "serviceable/issuable without qualification, new, used, repaired or reconditioned materiel which is serviceable and issuable to all customers without limitation or restriction, including materiel with more than 6 months shelf-life remaining." National Stock Number (NSN) 4110-01-107-9078 shall be known as the Refrigerator-Container.

1.1 Background. IROAN is defined as "That maintenance technique which determines the minimum repairs necessary to restore equipment components or assemblies to prescribed maintenance serviceability standards by utilizing all available diagnostic equipment and test procedures in order to minimize disassembly and parts replacement."

2.0 APPLICABLE DOCUMENTS. The following documents form a part of this SOW to the extent specified. Unless otherwise specified, the issues of these documents are those listed in the Department of Defense Index of Specifications and Standards (DoDISS) and supplement thereto which is in effect on the date of solicitation. In the event of conflict between the documents referenced herein and the contents of this SOW, the contents of this SOW shall be the superseding requirement.

2.1 Military Standards.

MIL-STD-129	DoD Standard Practice for Military Marking
MIL-STD-130	Identification Marking of U.S. Military Property
MIL-STD-2073-1D	DoD Standard Practice for Military Packaging

2.2 Other Government Documents and Publications. The issues of those documents cited below shall be used.

TM 08407A-13/1	Operation and Maintenance Refrigerator-Container, Field
SL-4-08407A	Refrigerator-Container, Field Repair Parts List
TM 3080-50	Corrosion Control Procedures Depot Maintenance Activities for Marine Corps Equipment

TM-4750-15/2	Painting and Registration Marking for Marine Corps Combat and Tactical Equipment
DOD 4000.25-1-M	MILSTRIP Manual
NAVICPINST 4491.2A	Requisitioning of Contractor Furnished Materiel From The Federal Supply System

Military Handbooks (For Guidance)

MIL-HDBK-61	Configuration Management Guidance
-------------	-----------------------------------

2.3 Industry Standards.

JESD625-A	Requirements for Handling Electrostatic-Discharge Sensitive (ESDS) Devices
ANSI/ISO/ASQC Q9002-1994	Quality Systems-Model for Quality Assurance in Production, Installation, and Servicing.

Industry Standards (For Guidance)

ANSI/EIA-649	National Consensus Standard for Configuration Management
--------------	---

Copies of Military Standards and Specifications are available from the DOD Single Stock Point, Document Automation and Production Service, Building 4/D, 700 Robbins Avenue, Philadelphia, PA 19111-5094, Telephone (215 697-2179 or DSN 442-2179, or <http://www.dodssp.daps.mil>. Copies of other government documents and publications required by contractors in connection with specific SOW requirements shall be obtained through the contracting officer: Commander, Marine Corps Logistics Bases, (Code 891), 814 Radford Blvd., Albany, Georgia 31704-1128, commercial telephone number (229) 639-6753 or DSN 567-6753. Copies of engineering drawings, if applicable, shall be obtained from Life Cycle Management Center, Attn: Code 851-3, 814 Radford Blvd., STE 20320, Albany, GA 31704-1128, commercial telephone number (229) 639-6410 or DSN 567-6410.

3.0 REQUIREMENTS.

3.1 General Tasks. In fulfilling the specified requirements, the Contractor shall:

a. Provide materials, labor, equipment, facilities and missing/repair parts, necessary to inspect, diagnose, restore, and test and calibrate the Refrigerator-Container. Upon completion of IROAN, the subject item shall be Condition Code "A".

b. Provide all tools and test equipment required to test, inspect, repair and calibrate the

Refrigerator-Container.

c. Conduct in process and final on-site testing for witness by a Marine Corps Logistics Bases (MCLB), Code 837-1 Albany, representative.

3.2 Detail Tasks. The following tasks describe the different phases for IROAN of the Refrigerator-Container.

3.2.1 Phase I- Pre-Induction. A Pre-Induction inspection analysis shall be performed for each Refrigerator-Container using the Contractor Facility's diagnosis, inspection and testing techniques, Marine Corps TM 08407A-13/1 and SL-4-08407A to determine extent of work and parts required. The findings of the Pre-Induction inspection shall be annotated on the Refrigerator-Container Pre-Induction Checklist (Appendix A) and shall be maintained and made available upon request by the Weapon System Manager, MCLB, Albany, (Code 837-1) and /or their representative. If the data is to be provided electronically to the Weapon System Manager (Code 837-1) and/or their representative, both the Weapon System Manager and the Contractor must agree to the database.

3.2.2 Phase II - IROAN. After Pre-Induction tests and inspections have been completed, repair of the Refrigerator-Container shall be accomplished in accordance with this SOW. Deficiencies noted on the Pre-Induction Checklist (Appendix A) during Phase I shall be repaired/replaced. Components or assemblies shall not be disassembled for replacement of parts unless that part has failed, or the component assembly wherein the part is located is disassembled for repair.

a. Pre-Induction Checklist (Appendix A) - Information recorded on the Pre-Induction Checklist shall be used as a guide to repair the Refrigerator-Container in accordance with this SOW.

b. Data plate - Each repaired Refrigerator-Container shall have an IROAN data plate affixed to the main unit in close proximity to the existing data plate. The data plate shall meet the requirements of MIL-STD-130 and TM-4750-15/2.

c. Hardware

(1) Replace broken, unserviceable and/or missing hardware including nuts, bolts, screws, washers, turn lock fasteners, mandatory replacement items, safety, and one-time use items, etc., in accordance with this SOW. Unserviceable would include any of the above that failed to function properly.

(2) Ensure proper hardware locking devices are present on all moving mechanical assemblies.

(3) Hardware normally supplied with commercial parts shall be used unless specifically prohibited.

d. Corrosion Control and Painting - Corrosion control preventatives shall be applied per TM 3080-50 and painting shall be accomplished per TM-4750-15/2.

3.2.3 Phase III - Inspection, Testing and Acceptance.

a. Inspection, Testing and Acceptance of the Refrigerator-Container shall be conducted in accordance with this SOW, Marine Corps TM 08407A-13/1 and SL-4-08407A.

b. The Contractor shall be responsible for conducting operational/acceptance testing and shall ensure all necessary personnel are available to complete the final acceptance testing. The final acceptance tests shall be held at the Contractor's facility. The Weapon System Manager (Code 837-1) and/or their representative shall be given a minimum of two weeks notice prior to beginning acceptance testing. The test area shall be set up with all safety considerations incorporated (test area clearly defined, limited access to unauthorized vehicles and foot traffic, etc.)

c. The Contractor shall be responsible for correcting any deficiencies identified during inspection/testing. MCLB Albany, Georgia, (Code 837-1), representatives may require the Contractor to repeat tests or portions thereof, if the original tests fail to demonstrate compliance with this SOW.

d. The operation Tests are to be conducted on each Refrigerator-Container, upon completion of repairs and prior to the equipment being returned to stock.

3.2.4 Phase IV - Packaging, Handling, Storage and Transportation (PHS&T).

a. The contractor shall be responsible for preservation and packaging of items being repaired under the terms of this statement of work. Items scheduled for long term storage or shipment to overseas destinations shall be packaged to the level "A" requirements of MIL-STD-2073-1D, Method 10. Items scheduled for domestic shipment, immediate use or short-term storage shall be to level B requirements.

b. Marking shall be in accordance with MIL-STD-129.

c. The Marine Corps will provide the contractor with the shipping address(es) for delivery of the repaired equipment. The contractor shall be responsible for arranging for shipment to the pre-designated site(s). The Marine Corps will be responsible for transportation costs associated with shipping the equipment to and from the Contractor.

3.3 Configuration Control. The contractor shall apply configuration control procedures to established configuration items. The contractor shall not implement configuration changes to an item's documented performance or design characteristics without prior written authorization. If it is necessary to temporarily depart from the authorized configuration, the contractor shall prepare and submit a Request For Deviation. MIL-HDBK-61 (paragraph 4.3 and Table 4-9) and

ANSI/EIA-649 (paragraph 5.3.4) provide guidance for preparing these configuration control documents.

3.4 Electrostatic Discharge (ESD) Control Program. The Contractor shall establish, implement and document an ESD control Program following the guidelines provided in JESD625-A. ESD protective measures shall be used during manufacturing, handling, inspection test, marking, packaging, storing and transporting ESD sensitive components.

3.5 Quality Assurance Provisions. The Contractor shall provide and maintain a Quality System that as a minimum, adheres to the requirements of ANSI/ISO/ASQC Q9002-1994, Quality Systems-Model for Quality Assurance in Production, Installation, and Servicing. The program shall ensure quality throughout all areas to include processing, assembly, inspection, test, maintenance, and preparation for delivery and shipping. Unless otherwise specified in the contract, the contractor shall be responsible for performance of all inspection requirements. The Government, Code 837-1, reserves the right to perform any of the inspections set forth in the contract where such inspections are deemed necessary to assure products and services conform to the prescribed requirements.

3.6 Acceptance. The performance of the Contractor and the quality of work delivered, including all equipment furnished and documentation written or compiled, shall be subject to in-process review and inspection during performance. Inspection may be accomplished in-plant or at any work site or location, and Marine Corps, Code 837-1, representatives shall be permitted to observe the work or to conduct an inspection. Final inspection and acceptance testing shall be conducted at the Contractor's Facility. Final acceptance shall be conducted on 100 percent of items to verify that the units meet all requirements.

3.7 Government Furnished Equipment (GFE)/Government Furnished Materiel (GFM). GFE is government owned equipment authorized by contract for use by a commercial/Government contractor. It is neither consumed during production nor incorporated into the product. GFM is materiel furnished to a contractor that will be consumed during the course of production or incorporated into the product being manufactured/remanufactured under a contract/statement of work. In the event the Marine Corps does have GFE/GFM requirements the Management Control Activity (MCA/Code 827-2), Marine Corps Logistics Bases, Albany, Georgia, will coordinate required GFE and will maintain a central control on Marine Corps assets in the Contractor's possession. The MCA will forward a GFE Accountability agreement to the Contractor Facility for signature to establish a chain of custody and property responsibilities for the Marine Corps assets.

3.8 Contractor Furnished Materiel (CFM). The Marine Corps has adopted the Navy's procedures regarding Contractor Furnished Materiel (NAVICPINST 4491.2A). In the event that Contractor Furnished Materiel (CFM) is required for repair parts, the contractor shall requisition repair parts through the DoD Supply System. DoD 4000.25-1-M (MILSTRIP), Chapter 11 authorizes contractors to requisition through the DoD Supply System.

3.9 Rejection Failure to comply with any of the specified requirements listed herein shall be reason for rejection by MCLB, Albany, (Code 837-1) representative. The Contractor shall, at no additional cost, correct the deficiencies and repeat the verification.

REFRIGERATOR-CONTAINER PRE-INDUCTION INSPECTION CHECKLIST

REFRIGERATOR-CONTAINER SERIAL NUMBER _____

CONDITION CODE UPON RECEIPT _____

CORROSION PREVENTION METHODS TO BE USED _____

REPAIR PARTS/ASSEMBLIES REQUIRED FOR REPAIRS

[illegible]

DEFECTIVE PARTS AND ASSEMBLIES

[illegible]

CONTRACT DATA REQUIREMENTS LIST

(1 Data Item)

Form Approved
OMB No. 1704-0188

The Public reporting burden for this collection of information is authorized to average 110 hours per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Department of Defense, Washington Headquarters Services, Directorate for Information Operations and Reports 1215 Jefferson Davis Highway, Suite 1214, Arlington, VA 22202-4302 and to the Office of Management and Budget, Paperwork Reduction Project (0704-0188), Washington, DC 20503. Please DO NOT RETURN your form to either of these addresses. Send completed form to the Government issuing Contract Officer for the contract/PR No. listed in block E.

A. CONTRACT LINE ITEM NO.	B. EXHIBIT	C. CATEGORY: TDP _____ TM _____ Other XXX _____
---------------------------	------------	--

D. SYSTEM/ITEM Refrigerator-Container, Field	E. CONTRACT/PR No.	F. CONTRACTOR
---	--------------------	---------------

1. DATA ITEM No. A001	2. TITLE OF DATA ITEM Request for Deviation (RFD)	3. SUBTITLE Configuration Management
--------------------------	--	---

4. AUTHORITY (Data Acquisition Document No.) DI-CMAN-80640C	5. CONTRACT REFERENCE Paragraph 3.3	6. REQUIRING OFFICE MARCORLOGBASES 851-2
--	--	---

7. DD 250 REQ. LT	9. DIST STATEMENT REQUIRED A	10. FREQUENCY AS REQ	12. DATE OF FIRST SUBMISSION See Blk 16	14. DISTRIBUTION a. ADDRESSEE	b. COPIES		
8. APP CODE		11. AS OF DATE	13. DATE OF SUBSEQUENT SUBMISSION		Draft	Reg	Repro

16. REMARKS Blk 4: Contractor format is authorized and shall be submitted in .doc and .pdf format. Blk 10 & 12: RFDs will be reviewed and disposition determined within 30 working days upon receipt by the government. RFDs shall be transmitted via e-mail to the following address: mbmatcomconfigmngmnt@matcom.usmc.mil Distribution Statement A: Approved for public release, distribution is unlimited.	MCLBA 851-2	0	1	0
	MCLBA 837-1	0	0	0
	15. TOTAL		1	

G. PREPARED BY: <i>Carl J. Hall</i>	H. DATE 03-25-00	I. APPROVED BY: <i>Carl J. Hall</i>	J. DATE 10/02/00
--	---------------------	--	---------------------

DD FORM 1423-1, AUG 96 (EG)

PREVIOUS EDITION MAY BE USED

Page 1 of 1 Pages
Designed using Perform Pro, WHS/D.or, Aug 96

17. PRICE GROUP

18. ESTIMATED
TOTAL PRICE